

LDBU Upgrading door bottom clearances

Description

This retro-fit seal is used to upgrade fire door assemblies that have a door bottom clearance that exceeds the 10mm specified in AS1905.1

Key benefits

Suitable for upgrading door bottom gaps up to 22mm. Cost savings for building owners as non-compliant fire door assemblies may be salvaged rather than replaced. Incorporates a waterproof high performance intumescent strip and silicone rubber gasket. Simple screw fix installation.

Approvals

Fire: Tested in accordance with AS1530.4 on proprietary fire doors.

Standard lengths

820mm, 920mm and 1220mm.

Fixing method

Screw fixed to door bottom.

Gap sizes

11mm - 24mm*. **please check with our technical department regarding fire door manufacturers maximum gap sizes*

Finish

Silver anodised aluminium with grey gasket.

